



U.T. Administration of
Dadra & Nagar Haveli and Daman & Diu,
Department of Fire & Emergency Services,
Fire Force Headquarters,
Daman - 396 215.
E-Mail ID: sfo-dmn-dd@nic.in



No. DFES/DMN/ Corrigendum/AR-AFFF/2019-20/95

Dated: 20/02/2020.

Read: 1. e-tender No. DFES/DMN/e-Tender/AR-AFFF/2019-20/146 dated 03-02-2020.

CORRIGENDUM

(Tender id No.2020_DAMAN_688_1)

In partial modification to the e-tender for supply of Alcohol Resistance Aqueous Film Foaming Foam (AR -AFFF) 3 x 3 %- C6 Concentrate quoted at preamble above, may please be read as under:

1. Technical Specification points:

Tender Clause/ page No.	Description as per tender document	Amendment
11.2 of Schedule-A & B and 8.2 of Schedule-C	Random sample of supplied Foam Concentrate shall be sent to any reputed laboratory (Third Party) in India, if desire by the Fire department and the payment will be done after satisfactory test report as per relevant standard (IS 4989:2018) (latest revision).	Random sample of supplied Foam Concentrate shall be sent to any reputed laboratory (Third Party) in India by the Fire department. The total cost of testing of foam concentrate shall bear by the bidder and the final payment will be released after satisfactory test report as per technical parameter of IS 4989:2018 (latest revision) received from third party lab.

Other contents of the Tender/technical specification will remain unchanged.

For and on Behalf of Director,
Fire & Emergency Services,
Dadra & Nagar Haveli and Daman & Diu.

Tender Inviting Officer,
Assistant Director,
Fire & Emergency Services,

Daman,
Date: 20/02/2020
Place: Daman

Copy to:-

1. PA to Hon. DIGP/Director of Fire & Emergency Services, DNH and Daman & Diu, Daman.
2. The District Informatics Officer, NIC, Daman for Publishing on website www.daman.nic.in for wide publicity.
3. All Head of Office, Daman.
4. Office copy.