

Administration of Daman & Diu (U.T.),
Deptt. of Fire & Emergency services,
Fire Force Headquarters, Somnath,
Daman - 396 215.
Email: sfo-dmn-dd@nic.in

File No. F-23019/1376/2019

Dated: 22/05/2019.

ADVISORY NOTICE
FOR VIOLATION OF FIRE PREVENTION AND FIRE SAFETY MEASURES

WHEREAS, a Notification No. DFS/DD/F.P.-Notification/2004-05/ 627 dated 12-01-2005 issued under sub-section (1) of Section 13 of the Goa, Daman and Diu Fire Force Act, 1986 (Act 9 of 1986) and under rule 24 of Daman and Diu Fire Force Rules 2004, the factories and establishment, storage place of flammable and Hazardous goods, petroleum product etc. Are required to take fire prevention and fire safety measures/Installations of fire fighting requirement as provided National Building Code of India and fire NOC is necessary for such places and trades.

ANDWHEREAS, it has come to the notice that the fire safety measures and Fire NOC of Fire Department are not taken in the above such premises and maximum numbers of plastics industries using petrochemical product in form of raw materials which is highly flammable nature.

ANDWHEREAS, further, it has been also observed that the almost industrial units are failed to keep open set back spaces clear for passage as per approved plan. The open spaces were stalked with various inventory materials, storage and structures erected with plastic/tarpoline shed due to while the fire fighting vehicles could not approached closer to the industrial structure. The plastic/tarpoline is fire prone materials as the easily spreading the fire within premises or adjoining industrial units.

NOW THEREFORE, all the relevant establishment should apply for the fire NOC and comply the fire safety measures within 03 months from the date of receipt this notice and no temporary structure erected in open spaces and it should be always cleared free from obstruction and encroachment as per approved plan for fire brigade access failing which punitive/penal action will be taken against you as per Goa, Daman and Diu Fire Force Act, 1986 (Act 9 of 1986), Daman and Diu Fire Force Rules 2004 and above notification dated 12/01/2005 which should be noted and also failing which your premises will be declared unsafe from the fire safety point of view.

Failure to comply may also result in Seizure, detention and removal of objects/goods likely to cause risk of fire under sub section (2) of section 13 of Goa, Daman and Diu Fire Force Act, 1986 (Act 9 of 1986).

RISHI PAL, DIR(FES)-RP, O/O DIRECTOR(FES)

Copy for necessary action to:-

1. The Secretary (Industries), Daman.
2. The Collector, Daman.
3. The General Manager, DIC, Daman.
4. The Chief Publicity Officer, Daman for vide publicity and publication in the local news papers and Electronics Media in Daman/Diu.
5. The Associate Town Planner, Daman.
6. Office copy